



# Certificat

## Certificate

Certificate of conformity with standard EN 14604  
SMOKE ALARM DEVICES

Issued in conformity with the transposition decree number n°92-647 of 8 July 1992, modified by the decree number n° 95-1051 of 20 September 1995 and the decree number n°2003-947 of 3 October 2003 concerning appropriate use of construction products and in conformity with article 14 (1) (b) of the Construction Products Directive 89/106/EEC of 21 December 1988 amended by the Directive 93/68/EEC of 22 July 1993.

### Delivered by :

Notified Body : AFNOR Certification  
Identification number : 0333  
Address : 11, rue Francis de Pressensé  
FR-93571 La Plaine Saint-Denis Cedex

### Delivered to :

Company : FARE  
Address : ZA de la Guinette  
Rue Duhamel du Monceau  
45300 DADONVILLE - FRANCE  
Manufacturing sites : FR – 45300 DADONVILLE  
152/1421 Zhuan Xing Dong Lu Minhang District, Shanghai – China

### Products : Smoke Alarm Devices – DO 4003

### Detailed description of products : Annex (1 page)

The product mentioned in annex is the object by the manufacturer of a factory production control and tests carried out on samples taken in the place of manufacture in accordance with a pre-established test plan.

AFNOR Certification carried out tests of the initial type on this products, the initial inspection of the site of production and the control of production in factory and carries out a continuous surveillance, evaluation and an acceptance of the control of production in factory.

This certificate attests that provisions concerning the attestation of conformity described in annex ZA of the standard EN 14604:2005 + AC : 2008 were applied and that the product fulfils all the requirements demands.  
It will allow the manufacturer or his agent operating within the EEA to apply EC marking.

Certificate number : 0333-CPD-292031

Conditions and certificate validity period : 05 December 2015

This certificate was first issued on 06 December 2010 and remains valid as long as the validity period and the conditions laid down in the harmonised technical specification in reference or the manufacturing conditions in the factory or the FPC itself are not modified significantly.

Date of issue of the certificate : 06 December 2010.

Deputy General Manager



Jacques BESLIN





# Certificat

## Certificate

Certificate of conformity with standard EN 14604  
Annex (1 page)

Company : **FARE**

Certificate number : **0333-CPD-292031**

Manufacturing site : **FR – 45300 DADONVILLE**  
**152/1421 Zhuan Xing Dong Lu Minhang District, Shanghai – China**

Date of certificate delivery : 06 December 2010.

### Product's description :

Identification of certified product (Reference)	Product designation in compliance with standard	File number
<b>DO 4003</b> Trademark : FARE	<b>Sensor type :</b> Smoke optical using scattered or transmitted light. <b>Power source :</b> Cell Alkaline 9V 630 mAh (models EVEREADY 522 or DURACELL MN1604) <b>Mounting :</b> Ceiling and wall <b>Option :</b> Individual alarm indicator, <b>Radio link :</b> Yes	292.0101

